

03.04.2020.
Uz

Nr. 2.5/2020/1291
Nr.

Sarunu procedūras pretendentiem/
Tenderers of the negotiated procedure

Par sarunu procedūru "110 kV iekārtu piegāde apakšstacijai "Krustpils"" - grozījumi nolikumā

Subject: Negotiation procedure "The supply of 110 kV electrical equipment for the substation "Krustpils"" - amendments to the regulations

Ar šo informējam, ka tiek veikti grozījumi sarunu procedūras "110 kV iekārtu piegāde apakšstacijai "Krustpils"" (Id.Nr.AST2020/19) nolikumā:

We are hereby informed that amendments are made to the terms in the negotiated procedure "The supply of 110 kV electrical equipment for the substation "Krustpils"" (Id. No AST2020/19):

Grozījums Nr.1
Amendment No 1

2. pielikums "Technical specifications" pozīcija 3.Single-column 72,5 kV earthing switches:

Annex 2 "Technical specifications" position 3.Single-column 72,5 kV earthing switches:

| Description: | Required: | Offered: |
|--|-----------|----------|
| Knife type single-column earthing switches, motor driven | 2 units | |
| Earthing switch provided for power transformer neutral point grounding | yes | |
| Rated short-time withstand current (3 s) | ≥ 25 kA | |
| Rated peak withstand current | ≥ 63 kA | |
| Rated voltage | 72,5kV | |
| Rated frequency | 50 Hz | |

tiek izteiktas šādā redakcijā:
are amended as follows:

| Description: | Required: | Offered: |
|--|-----------|----------|
| Knife type single-column earthing switches, motor driven | 2 units | |
| Earthing switch provided for power transformer neutral point grounding | yes | |
| Rated short-time withstand current (1 s) | ≥ 25 kA | |
| Rated peak withstand current | ≥ 63 kA | |
| Rated voltage | 72,5kV | |
| Rated frequency | 50 Hz | |

Šīs izmaiņas attiecināmas tikai uz zemējuma slēdzi 72,5 kV.
Please note that these changes only apply to Single column 72,5 kV earthing switches parameters.

Šis pielikums ir sarunu procedūras Nr.AST2019/11 nolikuma sastāvdaļa.
This addendum is part of the Regulations of negotiation procedure No.AST2019/11.

Kind regards,

Valdes loceklis/
Member of the Management Board



Mārcis Kauliņš

*AS "Augstsprieguma tīkls"
Chairman of the Board*

Varis Boks

Kundziņa 67725238