

14.05.2018.

Nr. 500300/2.5/2018/1822

Tenderers of the negotiated procedure

Subject: Negotiation procedure No AST2018/21 "The supply of a Phasor Measurement Unit (PMU)" - answers to the tenderer questions

Dear Sir/Madam!

Hereby the Customer answers to the tenderer questions.

Question 1: In technical specification item 1.18 required "Rated current: 1A, Shall withstand permanent overload: Current: 10A". Is it acceptable to use device with current withstand: continuous 4xlnom, 1 sec at 100 times rated, 20 ms at 250 times rated?

Answer: Yes, this is acceptable, if the device can withstand 10A for at least 10 seconds and there is official manufacturer statement on that.

Question 2: In technical specification item 1.23 required "PMU system devices, must have one of the following communication ports for parametrization with local PC: RS232, USB 2.0". Is it acceptable to use device with only RJ45 port for parametrization?

Answer: Yes, it is acceptable if this is second Ethernet port and is located on the front panel. The first Ethernet port will be permanently used for remote communication.

Yours faithfully

Member of the Management Board

Kapče 67725552

Maulu Mārcis Kauliņš

